

TAMILNADU FIRE AND RESCUE SERVICE DEPARTMENT

NO OBJECTION CERTIFICATE

LICENSE NO : 06/2025 Villivakkam Fire and Rescue
R.C.NO : 23/V/VLK/2025 Service Station
DATE : 20.02.2025

Subject: Fire and rescue service department - Villivakkam
Fire and Rescue Service Station for purpose of
No Objection certificate - reg

Ref: (1) G.O.No.122.School Edu(2) Dept, Date: 14.09.2004
(2) G.O.No.123 School Edu(2) Dept, Date: 14.09.2004
(3) Date of Requisition letter from the Principal,
ICF Vidyaniketan-19.02.2025

Based on the Govt. Order mentioned above and the requisition letter given by the ICF Vidyaniketan at Apprentice Avenue, ICF Colony, Konnur High Road, Chennai-600038, Tamil Nadu the building and premises comprises of owned/occupied by ICF Vidyaniketan have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 20.02.2025 in the presence of Principal and that the school is granted NOC for a period of one year from 20.02.2025 to 19.02.2026 subject to the conditions stated below.

THE ABOVE PREMISES INSPECTED BY STATION OFFICER FIRE & RESCUE SERVICES, A.RAMACHANDRAN ON 20.02.2025.

CONDITIONS

1. This License is valid for ONE YEAR from the date of issue
2. Fire Safety systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a. Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building code-2005

- b. The Staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children
- c. As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
- d. Periodical maintenance and care should be taken to maintain all fire protection equipments.
- e. Mock drill has to be conducted at regular intervals in consultation with the Divisional Officer, Fire and Rescue Services, Chennai City Central Division at Kilpauk.

If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



[Handwritten Signature]
நீலைய அலுவலர்
தீயணைப்பு மற்றும் மீட்பு பணிகள் நிலையம்
வில்லிவாக்கம், சென்னை-600 049.